



48 Spencer Street
Lebanon, NH 03766, USA
Tel: 603-448-1562
Fax: 603-448-3216
Email: geokon@geokon.com
<http://www.geokon.com>

Instruction Manual

Model 1280

A-6 Borehole Extensometer

No part of this instruction manual may be reproduced, by any means, without the written consent of Geokon®.

The information contained herein is believed to be accurate and reliable. However, Geokon® assumes no responsibility for errors, omissions or misinterpretation. The information herein is subject to change without notification.

Copyright © 2002-2019 by Geokon®
(Doc Rev I 06/19/2019)

Warranty Statement

Geokon warrants its products to be free of defects in materials and workmanship, under normal use and service for a period of 13 months from date of purchase. If the unit should malfunction, it must be returned to the factory for evaluation, freight prepaid. Upon examination by Geokon, if the unit is found to be defective, it will be repaired or replaced at no charge. However, the WARRANTY is VOID if the unit shows evidence of having been tampered with or shows evidence of being damaged as a result of excessive corrosion or current, heat, moisture or vibration, improper specification, misapplication, misuse or other operating conditions outside of Geokon's control. Components which wear or which are damaged by misuse are not warranted. This includes fuses and batteries.

Geokon manufactures scientific instruments whose misuse is potentially dangerous. The instruments are intended to be installed and used only by qualified personnel. There are no warranties except as stated herein. There are no other warranties, expressed or implied, including but not limited to the implied warranties of merchantability and of fitness for a particular purpose. Geokon is not responsible for any damages or losses caused to other equipment, whether direct, indirect, incidental, special or consequential which the purchaser may experience as a result of the installation or use of the product. The buyer's sole remedy for any breach of this agreement by Geokon or any breach of any warranty by Geokon shall not exceed the purchase price paid by the purchaser to Geokon for the unit or units, or equipment directly affected by such breach. Under no circumstances will Geokon reimburse the claimant for loss incurred in removing and/or reinstalling equipment.

Every precaution for accuracy has been taken in the preparation of manuals and/or software, however, Geokon neither assumes responsibility for any omissions or errors that may appear nor assumes liability for any damages or losses that result from the use of the products in accordance with the information contained in the manual or software.

TABLE of CONTENTS

1. INTRODUCTION	1
2. PRELIMINARY REQUIREMENTS	2
2.1 BOREHOLE REQUIREMENTS	2
2.2 ANCHOR SPACING	2
2.3 INSTRUMENT HEAD PROTECTION	2
2.4 SWAGELOK TUBE FITTING INSTRUCTIONS	3
2.4.1 Installation	3
2.4.2 Reassembly Instructions	4
2.5 LIST OF INSTALLATION TOOLS REQUIRED	5
3. INSTALLATION	6
3.1 STANDARD GROUTABLE SYSTEM WITH MANUAL READOUT – DOWNWARD DIRECTED BOREHOLES	6
3.2 STANDARD GROUTABLE SYSTEM WITH MANUAL READOUT – UPWARD DIRECTED BOREHOLES	7
3.3 STANDARD HYDRAULIC SYSTEM WITH MANUAL READOUT	9
4. ADJUSTING ANCHOR DEPTHS	10
4.1 SHORTENING THE RODS AND TUBES – GROUTABLE AND HYDRAULIC ANCHORS	10
4.2 LENGTHENING THE RODS AND TUBES – GROUTABLE AND HYDRAULIC ANCHORS	11
5. ELECTRONIC READOUT - VIBRATING WIRE DISPLACEMENT TRANSDUCERS	12
5.1 ELECTRONIC READOUT ONLY	12
5.2 ELECTRONIC READOUT WITH MANUAL READOUT CAPABILITY	13
6. TAKING READINGS	15
6.1 MANUAL READINGS	15
6.2 ELECTRONIC READOUT	15
6.3 GK-404 READOUT BOX	15
6.3.1 Operating the GK-404	15
6.4 GK-405 READOUT BOX	17
6.4.1 Connecting Sensors with 10-pin Bulkhead Connectors Attached	17
6.4.2 Connecting Sensors with Bare Leads	17
6.4.3 Operating the GK-405	17
6.5 GK-403 READOUT BOX (OBSOLETE MODEL)	18
6.5.1 Connecting Sensors with 10-pin Bulkhead Connectors Attached	18
6.5.2 Connecting Sensors with Bare Leads	18
6.5.3 Operating the GK-403	18
7. DATA ANALYSIS	19
7.1 EXAMPLE OF MPBX DATA REDUCTION WHERE THE DEEP ANCHOR IS IN STABLE GROUND	19
8. TROUBLESHOOTING	22
8.1 DIAL INDICATORS	22
8.2 VIBRATING WIRE TRANSDUCERS	22
APPENDIX A. WIRING CHARTS FOR VIBRATING WIRE TRANSDUCERS	23
A.1 SINGLE TRANSDUCER WIRING CHART	23
A.2 TWO TRANSDUCER WIRING CHART	23
A.3 THREE TRANSDUCERS WIRING CHART	23
A.4 FOUR TRANSDUCERS WIRING CHART	24
A.5 FIVE TRANSDUCERS WIRING CHART	24
A.6 SIX TRANSDUCERS WIRING CHART	25
A.7 SEVEN TRANSDUCERS WIRING CHART	25
A.8 EIGHT TRANSDUCERS WIRING CHART	26
APPENDIX B. SPECIFICATIONS	27

B.1 MODEL 1280 SPECIFICATIONS.....	27
B.2 MODEL 4450 VIBRATING WIRE TRANSDUCER SPECIFICATIONS.....	27
APPENDIX C. THERMISTOR TEMPERATURE DERIVATION.....	28
APPENDIX D. USING A PULL-IN ANCHOR IN DEEP BOREHOLES	29

FIGURES

FIGURE 1 - TUBE INSERTION.....	3
FIGURE 2 - MAKE A MARK AT SIX O’CLOCK.....	3
FIGURE 3 - TIGHTEN ONE AND ONE-QUARTER TURNS.....	3
FIGURE 4 - MARKS FOR REASSEMBLY.....	4
FIGURE 5 - FERRULES SEATED AGAINST FITTING BODY.....	4
FIGURE 6 - TIGHTEN NUT SLIGHTLY.....	4
FIGURE 7 - TYPICAL A-6 EXTENSOMETER.....	6
FIGURE 8 - UPWARDS INSTALLATION ASSEMBLY.....	7
FIGURE 9 - TYPICAL GROUTABLE ANCHOR.....	10
FIGURE 10 - MPBX WITH ELECTRONIC READOUT ONLY.....	12
FIGURE 11 - MPBX WITH MANUAL AND ELECTRONIC READOUT CAPABILITY.....	13
FIGURE 12 - LEMO CONNECTOR TO GK-404.....	16
FIGURE 13 - LIVE READINGS – RAW READINGS.....	17
FIGURE 14 - MOVEMENT OF THE HEAD AND ANCHORS RELATIVE TO ANCHOR 3 IN STABLE GROUND.....	21
FIGURE 15 - MOVEMENTS OCCURRING IN EACH INTER-ANCHOR ZONE.....	21

TABLES

TABLE 1 - RAW DATA.....	19
TABLE 2 - RELATIVE MOVEMENT BETWEEN THE INSTRUMENT HEAD AND EACH ANCHOR.....	20
TABLE 3 - MOVEMENT OF THE INSTRUMENT HEAD AND ANCHORS RELATIVE TO ANCHOR 3 IN STABLE GROUND.....	20
TABLE 4 - WIRING FOR ONE TRANSDUCER.....	23
TABLE 5 - WIRING FOR TWO TRANSDUCERS.....	23
TABLE 6 - WIRING FOR THREE TRANSDUCERS.....	23
TABLE 7 - WIRING FOR FOUR TRANSDUCERS.....	24
TABLE 8 - WIRING FOR FIVE TRANSDUCERS.....	24
TABLE 9 - WIRING FOR SIX TRANSDUCERS.....	25
TABLE 10 - WIRING FOR SEVEN TRANSDUCERS.....	25
TABLE 11 - WIRING FOR EIGHT TRANSDUCERS.....	26
TABLE 12 - A-6 EXTENSOMETER SPECIFICATIONS.....	27
TABLE 13 - MODEL 4450 DISPLACEMENT TRANSDUCER SPECIFICATIONS.....	27
TABLE 14 - THERMISTOR RESISTANCE VERSUS TEMPERATURE.....	28

EQUATIONS

EQUATION 1 - RESISTANCE TO TEMPERATURE.....	28
---	----

1. INTRODUCTION

The Model A-6 Multiple Position Borehole Extensometer, (MPBX), is made up of three to four basic components:

1) Borehole anchors

Borehole anchors may be either groutable or hydraulic types. The groutable type is usually recommended for downward directed boreholes or for holes that must remain sealed. Special equipment will be required for grouting boreholes directed upwards. Hydraulic anchors can be used anywhere and are particularly suited for use in upward directed boreholes. Usually the number of anchors lies between one and six.

2) Connecting rods and tubing:

The standard connecting rod is made from 1/4-inch fiberglass encased in 1/2-inch polyethylene tubing for borehole lengths less than 30 meters, or 1/2-inch nylon tubing for borehole depths greater than 30 meters. The flexibility of the rods and tubing allows the extensometer to be preassembled and coiled at the factory for shipment to the jobsite where it can be uncoiled and inserted into the borehole. This greatly speeds up the installation process.

3) Extensometer head assembly:

Various styles of head assemblies are available. The head may be designed for recessing into an enlarged section of the borehole or it may have a flange for mounting to a standpipe grouted into the mouth of the borehole. Provision may be made for manual or electronic readout or for both. Manual readout is by a 50 mm range dial indicator.

4) Electronic displacement transducers (optional):

The standard transducer is the model 4450 vibrating wire displacement transducer with ranges of 25, 50, or 100 mm. Linear potentiometers are also available.

2. PRELIMINARY REQUIREMENTS

2.1 Borehole Requirements

The Model A-6 is designed to fit 75 mm (3") or larger diameter boreholes. The mouth of the borehole may be cased with a two-and-a-half-inch standpipe or enlarged to take a three or three-and-a-half-inch standpipe, or it may be left free. Boreholes should be free of debris and drilled slightly longer (60 cm/2 ft.) than the deepest anchor.

2.2 Anchor Spacing

Anchor spacing is sometimes dictated by geologic features and by the size and geometry of the rock mass being monitored. Drill cores can be inspected to reveal zones and planes of weakness, which would suggest appropriate anchor locations. At least one anchor, usually the deepest anchor, should be installed in stable ground so that it can serve as a nonmoving point of reference for the rest of the anchors. For extensometers installed in tunnels the deepest anchor should be located at least one tunnel diameter, and preferably nearer two tunnel diameters, away from the tunnel opening.

2.3 Instrument Head Protection

The instrument head should be protected from damage. This may require recessing the instrument head inside the borehole to avoid blasting damage or, in exposed locations the construction of a protective enclosure, to ward against falling objects, moving equipment and vandalism.

MPBX heads installed downwards from street level are best contained within manholes with access covers. The manhole should be large enough to accommodate the instrument head and any datalogger that may be in use. The minimum size of manhole is 300 mm (12 inch). A better size is 550 mm (22 inch) diameter. Covers may be equipped with a locking device. The manhole should be provided with a drain so that it cannot become filled with rainwater.

Heads may be equipped with a flange to engage the flange on top of any standpipe grouted into the mouth of the borehole. This arrangement works well with groutable anchors. Where hydraulic anchors are in use, the instrument head comes equipped with its own hydraulic anchor, so standpipes and flanges are not always required.

2.4 Swagelok Tube Fitting Instructions

These instructions apply to one inch (25 mm) and smaller fittings.

2.4.1 Installation

- 1) Fully insert the tube into the fitting until it bumps against the shoulder.




Figure 1 - Tube Insertion

- 2) Rotate the nut until it is finger-tight. (For high-pressure applications as well as high-safety-factor systems, further tighten the nut until the tube will not turn by hand or move axially in the fitting.)
- 3) Mark the nut at the six o'clock position.




Figure 2 - Make a Mark at Six O'clock

- 4) While holding the fitting body steady, tighten the nut one and one-quarter turns until the mark is at the nine o'clock position. (Note: For 1/16", 1/8", 3/16" and 2, 3, and 4 mm fittings, tighten the nut three-quarters of a turn until the mark is at the three o'clock position.)




Figure 3 - Tighten One and One-Quarter Turns

2.4.2 Reassembly Instructions

Swagelok tube fittings may be disassembled and reassembled many times.

Warning: Always depressurize the system before disassembling a Swagelok tube fitting.

- 1) Prior to disassembly, mark the tube at the back of the nut, then make a line along the nut and fitting body flats. *These marks will be used during reassembly to ensure the nut is returned to its current position.*




Figure 4 - Marks for Reassembly

- 2) Disassemble the fitting.
- 3) Inspect the ferrules for damage and replace if necessary. **If the ferrules are replaced the connector should be treated as a new assembly. Refer to the section above for installation instructions.**
- 4) Reassemble the fitting by inserting the tube with preswaged ferrules into the fitting until the front ferrule seats against the fitting body.




Figure 5 - Ferrules Seated Against Fitting Body

- 5) While holding the fitting body steady, rotate the nut with a wrench to the previous position as indicated by the marks on the tube and the connector. At this point, there will be a significant increase in resistance.
- 6) Tighten the nut slightly.




Figure 6 - Tighten Nut Slightly

2.5 List of Installation Tools Required

Note: Installation Tool kits may be purchased as an accessory. They may include the following:

1. Two pair of Vise Grips
2. Adjustable wrenches
3. Screw Drivers
4. Allen Wrenches
5. Hacksaw
6. Files
7. Tape measure
8. Marking Pens
9. Loctite adhesive
10. PVC Cement
11. PVC Primer
12. Quick Setting Cement
13. Grout Plate (Normally Supplied)
14. Water (For flushing and grouting)
15. Sharp Knife
16. Tape (Filament)
17. Tape (Duct)
18. Spare parts –Swagelok Connectors and spare ferrules, O-rings, setscrews, bolts, screws, etc. (Normally shipped with the extensometer parts.)

With Groutable Anchors: Masking Tape, Grout Pump, Grout Tube and fittings, Type II Portland cement.

With Hydraulic Anchors: Hydraulic hand pump with pressure gauge and fittings.

3. INSTALLATION

3.1 Standard Groutable System with Manual Readout – Downward Directed Boreholes

A typical system is shown in Figure 7.




Figure 7 - Typical A-6 Extensometer

- 1) Normally, the MPBX is shipped preassembled and coiled for shipment. *Care should be taken when removing the tape holding the coils.* Release one coil at a time and keep a tight grip on the rest of the coils so that they cannot suddenly break free and uncoil violently. **Do not cut the tapes bundling the rod/tubes together.** Lay out the MPBX on a flat dry surface, as close to the borehole as possible.
- 2) If a Standpipe is to be installed it should be assembled now. Glue the Coupling, (or Flange), to the standpipe using PVC purple primer and cement. Apply quick-setting cement on the outside of the standpipe and insert into the borehole to the desired depth. Hold in place until the cement hardens, using wooden wedges or sackcloth soaked in quick-setting cement, as required.
- 3) If the anchor depths need to be adjusted from those set at the factory see Section 4.
- 4) The MPBX is shipped with the Grout Tube coiled separately it should now be uncoiled and pushed through the hole on the center of the Grout Plate and attached lightly to the deepest anchor only. Use enough masking tape so that it will not scrape off when the MPBX is pushed into the hole, but not so much that it cannot be broken free when grouting commences.
- 5) Slide the MPBX into the borehole until the Tube Mount is about to enter the coupling (or flange), be careful not to bend the MPBX in too tight a radius. Add PVC cement to the outside of the Tube Mount where it seats inside the standpipe coupling. Push the Tube Mount inside the coupling and allow the PVC cement to harden. (If flanges are used instead of couplings, glue the tube mount to the tube mount flange, then bolt this flange to the flange on the standpipe using the bolts supplied).

- 6) Connect the grout pipe to a grout pump and pump a little water through the grout line to lubricate it. Mix up a batch of cement grout with the consistency of pancake batter. Use Portland Type II cement mixed with water in approximately one to one mixture. Do not use any sand. Pump the grout into the borehole while slowly pulling the grout tube from the borehole. If the grout tube is to be used again, flush it now with water.
- 7) After the grout has set up, remove the grout plate and replace it with the Reference Surface. Be careful to match the numbers stamped on the Tube Mount with those on the Reference Surface. Take initial readings with the dial indicator and record. Screw on the Protective Pipe Cap to protect the Reference Surface.

3.2 Standard Groutable System with Manual Readout – Upward Directed Boreholes

Upward directed boreholes require special grouting techniques.

- 1) Normally, the MPBX is shipped complete, preassembled, and coiled for shipment. *Care should be taken when removing the tape holding the coils.* Release one coil at a time and keep a tight grip on the rest of the coils so that they cannot suddenly break free and uncoil violently. **Do not cut the tapes bundling the rod/tubes together.** Lay out the MPBX on a flat dry surface, as close to the borehole as possible.
- 2) The standpipe should be assembled first. Glue the coupling, (or flange), to the standpipe using PVC purple primer and cement. Apply quick-setting cement on the outside of the standpipe and insert into the borehole to the desired depth. Use plenty of cement to ensure a grout-tight seal around the standpipe. Hold in place until the cement hardens, using wooden wedges or sackcloth soaked in quick-setting cement, as required.
- 3) If the anchor depths need to be adjusted from those set at the factory see Section 4.
- 4) Referring to the numbers in Figure 8 as a guide, complete the following: Screw the down-hole grout pipe(7) into the back of the Tube Mount. Screw the external grout pipe(8) into the front of the Tube Mount. Thread the vent tube(6) through these two pipes and tape to the deepest borehole anchor so that it protrudes beyond the anchor by a distance of about 30 centimeters. Now slide the Valve/Tee assembly, (1-5), over the vent tube and screw onto the external grout tube. Tighten the Swagelok fitting, (1), onto the vent tube according to the instructions in Section 2.4.




Figure 8 - Upwards Installation Assembly

5) Push the entire assembly into the borehole until the head assembly is about to enter the standpipe, be careful not to bend the MPBX in too tight a radius. Add PVC cement to the outside of the head where it seats inside the standpipe coupling. Push the head inside the coupling and allow the PVC cement to harden. (If bolted flanges are used instead of cemented couplings, apply RTV sealant to one of the flange faces then bolt the flange on the head to the flange on the standpipe using the bolts supplied).

6) Because of the high pressures involved, the grouting must be done in two stages: The first stage is to grout the first meter and a half, (five feet), of the borehole in order to form a plug, which can seal the borehole and permit the rest of the hole to be grouted. Calculate the amount of grout required to do this. Connect the grout pipe to the gate valve and to a grout pump. Mix up the calculated amount of cement grout with the consistency of pancake batter. (Use Portland Type II cement and water in about a one to one mix.) Do not use any sand. With the valve open, pump the measured amount of grout into the borehole. With the valve still open, remove the grout pipe and allow any excess grout, above the level of the end of the down-hole grout pipe inside the borehole, to drain away. Reconnect a water supply to the Valve/Tee assembly and pump a few liters (gallons) of water into the borehole then disconnect the water supply and allow the water to flow back out of the hole and flush the system ready for the second stage of grouting. Allow the grout 24 hours to set up.

7) After the first stage grout plug has set up, reconnect the grout pump and pump grout until grout is seen exiting the vent tube. (Excessive grout pressures should be avoided since there is a danger of blowing out the plug). When grout is seen issuing from the vent line stop pumping, close the Gate Valve, and disconnect the pump. (In fractured ground, there may be some leakage into the fractures causing the top anchor to lose grouting. To ward against this, the pump can be left connected and grouting can be continued at intervals until, on recommencing the pumping, the grout is seen to flow immediately from the vent tube at which point the grout column is probably complete and covering the top anchor.)

8) After allowing enough time for the grout to harden, the grout pipe Valve/Tee assembly should be unscrewed from the MPBX head, or cut off flush with the MPBX head, and discarded. Remove the grout plate and replace it with the Reference Surface. Take initial readings with the dial indicator and record. Screw on the Protective Pipe Cap to protect the Reference Surface.

3.3 Standard Hydraulic System with Manual Readout

Hydraulic anchors may be of the Bladder type or of the Borros type.

- 1) A standpipe, made from steel or PVC pipe, is not usually required except where the mouth of the borehole is fractured, oversized, or irregular. If a standpipe is needed to stabilize the borehole collar, then the mouth of the borehole may have to be enlarged so that standpipe used can have at least the same I.D. as the rest of the borehole. Apply quick-setting cement on the outside of the standpipe and insert into the borehole to the desired depth. Hold in place until the cement hardens, using wooden wedges or sackcloth soaked in quick-setting cement, as required.
- 2) Normally, the MPBX is shipped complete, preassembled, and coiled for shipment. *Care should be taken when removing the tape holding the coils.* Release one coil at a time and keep a tight grip on the rest of the coils so that they cannot suddenly break free and uncoil violently. Lay out the MPBX on a flat dry surface, as close to the borehole as possible.
- 3) If the anchor depths need to be adjusted from those set at the factory see Section 4.
- 4) Push the MPBX into the borehole until the hydraulic anchor on the head assembly is well inside the borehole, (or inside the standpipe if one is used), be careful not to bend the MPBX in too tight a radius. For deep boreholes, requiring a pull-in anchor, see Additional instructions in Appendix D.
- 5) The hydraulic anchors are expanded beginning with the deepest anchor. (Anchors are numbered so that the shallowest anchor is Anchor #1. and the anchor with the highest number will be deepest in the hole.) If the end of the hydraulic tubing is plugged by a nail, cut off about 20 mm of the tubing and attach one of the 1/8-inch Swagelok tube fittings. When tightening Swagelok fittings follow the instructions in Section 2.4. Do not overtighten the Swagelok as this may pinch the tube shut. If the end of the tube is already sealed by a Swagelok tube fitting, remove the cap. Connect the hydraulic line to the hand-pump filled with hydraulic oil and inflate the cells. Watch the pressure gauge while pumping and be sure never to exceed a pressure of 17 MPa (2500 psi). More pressure than this can burst the tubing. (It takes about 5 MPa to begin to inflate the copper bladder on the Bladder type anchor or to drive out the prongs on the Borros type anchor). Continue pumping until the anchor pressure holds steady at about 9 MPa (1300 psi). Disconnect the hydraulic pump – the check valve at the anchor will maintain the anchor pressure. (Note: tests have shown that the anchor will continue to hold even if the anchor pressure drops to zero).
- 6) Repeat this process for the rest of the anchors, in descending numerical order, and for the anchor on the MPBX Head.
- 7) Take initial readings with the dial indicator and record. Screw on the Protective Pipe Cap to protect the Reference Surface

4. ADJUSTING ANCHOR DEPTHS

Occasionally, unforeseen site conditions may require the anchor depths to be adjusted. This will require the rods and tubes to be either lengthened or shortened.




Figure 9 - Typical Groutable Anchor

4.1 Shortening the Rods and Tubes – Groutable and Hydraulic Anchors

- 1) With the MPBX uncoiled on a flat surface, measure the amount to be shortened, from the hose barb on the anchor along the 1/2-inch O.D. poly tubing then mark the tubing. Next, with a sharp knife, cut only the tubing at this mark. Do not cut the fiberglass rod.
- 2) Loosen the Swagelok Connector on the outer end of the anchor and remove the nut and ferrules (olives) from around the fiberglass rod.
- 3) Pull the anchor and the piece of tubing already cut off, from off the fiberglass rod. Remove this piece of tubing from the hose barb and discard.
- 4) Slide the anchor back over the fiberglass rod and reattach the poly tubing to the hose barb. (If necessary, warm the poly tubing to make this easier.) Slide a new set of ferrules and nut over the fiberglass rod and tighten to the Swagelok fitting on the anchor per the instructions in Section 2.4. Make sure that the two parts of the ferrule are correctly oriented and positioned.
- 5) Saw off the excess fiberglass rod protruding from the anchor with a hacksaw.

4.2 Lengthening the rods and tubes – groutable and hydraulic anchors

This procedure requires the use of special factory supplied extension kit, which includes fiberglass rod extensions, of the correct length, poly tubing, and barbed tube fittings.

- 1) With the MPBX uncoiled on a flat surface remove the grout plate (or Reference Surface) from the MPBX head, loosen the Swagelok fitting on the outer end of the anchor and remove the nut and ferrules (olives) and then push the fiberglass rod through the anchor until the other end protrudes from the MPBX head.
- 2) Disconnect the anchor from the poly tube at the barb fitting on the anchor, (cut the tubing if necessary). Connect the correctly measured length of extension poly tube that will position the anchor at its new depth, to the rest of the tubing using a barb/barb fitting, then reconnect this extended tubing to the barb fitting on the anchor. Warming the poly tube so that it softens will facilitate the connection.
- 3) Connect the fiberglass extension rod to the threaded end of the fiberglass rod at the MPBX head end. Use Loctite on the threads. Push the extension rod into the MPBX head until the tip is positioned at the same depth as before. Slide new ferrules and the nut onto the fiberglass rod and then tighten the Swagelok fitting on the anchor so that it grips the rod. (See Section 2.4 for Swagelok instructions.)
- 4) Usually there is enough extra hydraulic tubing supplied with the hydraulic anchors that the end of the hydraulic tubing will remain accessible. If this is not the case, then the hydraulic tubing must be extended using a 1/8-inch Swagelok tube/tube connector.
- 5) Replace either the Grout Plate or the Reference Surface.

5. ELECTRONIC READOUT - VIBRATING WIRE DISPLACEMENT TRANSDUCERS

Electronic readout is usually accomplished by means of transducers and a transducer housing that are assembled and bolted to the MPBX head after the initial installation of the anchors and head has been performed. There are many variations and specific and detailed instructions are supplied with each extensometer. The following instructions apply, in a general way only, to the two main standard designs: one that permits electronic readout only and one that permits both electronic and manual readout. These general instructions will serve as an explanation for the more detailed instruction and why they are necessary.

5.1 Electronic Readout Only

A typical MPBX head assembly, designed to accept vibrating wire displacement transducers is shown in Figure 10.




Figure 10 - MPBX with Electronic Readout Only

- 1) The Guide Tubes provide a space in which the transducers are located. They may be shipped separately from the coiled fiberglass rods and tubes. If shipped separately then they must be first attached, first to the Tube Mount by threading and/or gluing, and then attached to the uncoiled tubing with Hose Barbs after a specified amount of the uncoiled tubing has been removed. The amount to be removed is such that when the fiberglass rod is connected to the transducer the transducer will be correctly positioned within the Guide Tube. Numbers stamped on the Tube Mount ensure that the correct anchor is connected to the corresponding Guide Tube and transducer.
- 2) If a Standpipe is in use, the rods and anchors are pushed into the borehole and the Tube Mount, with its Guide Tubes, is now glued to the standpipe. Extension Rods are screwed onto the end of the fiberglass rods and are then fastened to the Tube Mount by Temporary Swagelok Connectors. (See Section 2.4 for Swagelok instructions.) The extension rods are designed to hold the ends of the fiberglass rods in their correct positions relative to the head of the MPBX while the anchors and rods are being installed inside the borehole. Without them the friction and pull of the anchors during installation could move the rod tips by an unacceptable amount.

- 3) After the installations have been made as per the instructions of Section 3, the extension rods and Temporary Swagelok Connectors are removed. For hydraulic anchors it may be necessary to cut off the ends of the hydraulic lines and cap the hole on the Tube Mount with a pipe plug.
- 4) The Transducer Housing can now be bolted to the Tube Mount using the numbers stamped on the tube mount to ensure correct orientation.
- 5) Vibrating Wire Displacement Transducers are now threaded onto the end of the fiberglass rod tips. **Be sure the pin in the Transducer shaft is in the notch on the transducer when the Transducer is screwed onto the rod tip. If the pin is not in the notch when the Transducer is twisted, then serious damage can result.** Once connected, they can then be extended to the correct part of their range before being gripped by the Swagelok fittings in the Transducer Housing.
- 6) The installation is completed, by connecting the individual transducer leads to the main cable connector inside the MPBX Head and bolting the Housing Cover to the Transducer Housing using the long Standoff Bolts provided. Wiring Charts are given in Appendix A.
- 7) Initial Readings can now be taken.

5.2 Electronic Readout with Manual Readout Capability

A typical MPBX head assembly, designed to accept vibrating wire displacement transducers as well as permit manual readout is shown in Figure 11. In this arrangement, the transducers are not directly in line with the fiberglass rods but, instead, are recessed in guide tubes alongside the rods, leaving the tip of the rods free to be sensed by a dial indicator. Because of this design, when a rod is pulled the shaft of the transducer will retract, causing a decrease in the vibrating wire reading.




Figure 11 - MPBX with Manual and Electronic Readout Capability

- 1) The Tube Mount, if not shipped already connected to the fiberglass rods and tubes, must first be separated from the MPBX Head Assembly by removing the cap and unbolting the Tube Mount from the Transducer Housing. The Guide Tubes provide a space in which the transducers are located and are shipped already attached to the Tube Mount. Where groutable anchors are to be installed, these Guide Tubes need to be kept clean and should now be plugged with the O-ring plugs provided.
- 2) After uncoiling the fiberglass rods and poly tubing, the poly tubing, (if not already connected), is connected to the Tube Mount with Hose Barbs after a specified amount of the uncoiled tubing has been removed. The amount to be removed is such that when the installation is completed the tip of the fiberglass rod will be in the correct position relative to the Reference Surface. Numbers stamped on the Tube Mount ensure that the anchors are connected in the proper sequence.
- 3) Stainless steel Extension Rods are screwed, finger tight onto the end of the fiberglass rods and are then held to the Tube Mount by Temporary Swagelok fittings tightened onto the extension rods. (See Section 2.4 for Swagelok instructions.) The extension rods are designed to hold the ends of the fiberglass rods in their correct positions relative to the head of the MPBX while the anchors and rods are being installed inside the borehole. Without them the friction and pull of the anchors during installation could move the rod tips by an unacceptable amount.
- 4) If a Standpipe is in use it should be installed now, after which the installation may proceed in accordance with the instructions of Section 3.
- 5) After the installation of the fiberglass rods, poly tubes, and anchors is completed, then the Temporary Swagelok fittings and extension rods can be removed. The stainless steel Manual Readout Rods are connected to the end of the fiberglass rods. Tapered Bullets are threaded onto the outer ends of the Manual Readout Rods so that the Transducer Housing can now be slid over these rods, without damaging the O-ring Seals in the Transducer Housing. The Transducer Housing can now be bolted to the Tube Mount.
- 6) The Vibrating Wire Transducers can now be installed inside the Guide Tubes by removing the O-ring Plugs and then threading the Transducers onto the setscrew in the bottom of the Guide Tube. **Be sure the pin in the Transducer shaft is in the notch on the transducer when the Transducer is screwed onto the rod tip. If the pin is not in the notch when the Transducer is twisted, then serious damage can result.** The Transducer Clamps are slid over the Manual Readout Rods and secured to the backs of their corresponding Transducers. Each Transducer is connected in turn to a Readout Box and the Transducer is set in the desired part of its range. In most instances, where the movements being monitored are extensions, this will mean that the Vibrating Wire Transducer will be almost fully extended. When the correct position is selected then the setscrew in the Transducer Clamp is tightened onto the Manual Readout Rod.
- 7) The bullets are removed from the end of the Manual Readout Rods and replaced by Swagelok Caps, which will provide a large flat surface for the dial indicator tip to find.
- 8) The individual transducer leads are connected to the main cable connector and the Standoffs and Cap are replaced. Wiring Charts are given in Appendix A.
- 9) Initial readings can now be taken – both manual and electronic.

6. TAKING READINGS

An important note: For MPBX models designed for electronic readout only, when a rod is pulled the transducer shaft will extend, and the vibrating wire reading will increase. For MPBX models designed for electronic *and* manual readout, when a rod is pulled the transducer shaft will retract, and the vibrating wire reading will decrease.

The most important reading is the first reading; it is the base reading to which all subsequent readings will be compared. Verify that the readings are correct. If possible, install the MPBX well ahead of the time that movements are expected so that the MPBX has time to stabilize. (Most installations are subject to a “bedding-in” process during which slight movements can occur. These movements generally cease after two or three days). Often the best results can be obtained by using as the base line readings the readings taken on the third day. This, of course may not be possible if the ground is already moving.

6.1 Manual Readings

Manual readings are best taken using a dial indicator, although, depth micrometers have also been used. To take manual readings simply poke the stem of the indicator through the holes in the Cap on the MPBX Head assembly until the tip bears against the underlying Swagelok Cap. With the collar of the dial indicator held flush against the MPBX Cap or the Reference Surface take a reading on the indicator.

6.2 Electronic Readout

Readout frequency should be suitable to the purpose for which the readings are being made. All readings should be compared with previous readings as soon as they are taken. In this way, sudden changes of readings can be instantly checked to see if they are real or perhaps a reading error. If the changes are real, then the observer is alerted to the possibility of serious ground movements, or to possible instrument damage, and can look for further evidence of either.

6.3 GK-404 Readout Box

The Model GK-404 Vibrating Wire Readout is a portable, low-power, handheld unit that can run continuously for more than 20 hours on two AA batteries. It is designed for the readout of all Geokon vibrating wire gauges and transducers; and is capable of displaying the reading in either digits, frequency (Hz), period (μ s), or microstrain ($\mu\epsilon$). The GK-404 also displays the temperature of the transducer (embedded thermistor) with a resolution of 0.1 °C.

6.3.1 Operating the GK-404

Before use, attach the flying leads to the GK-404 by aligning the red circle on the silver “Lemo” connector of the flying leads with the red line on the top of the GK-404, as shown in Figure 12 below. Insert the Lemo connector into the GK-404 until it locks into place.



Figure 12 - Lemo Connector to GK-404

Connect each of the clips on the leads to the matching colors of the sensor conductors, with blue representing the shield (bare).

To turn the GK-404 on, press the “ON/OFF” button on the front panel of the unit. The initial startup screen will display:

Geokon Inc.
GK-404 verX.XX

After approximately one second, the GK-404 will start taking readings and display them based on the settings of the POS and MODE buttons.

The unit display (from left to right) is as follows:

- The current Position: Set by the **POS** button, displayed as a letter A through F.
- The current Reading: Set by the **MODE** button, displayed as a numeric value followed by the unit of measure.
- Temperature reading of the attached gauge in degrees Celsius.

Use the **POS** button to select position **B** and the **MODE** button to select **Dg** (digits). (Other functions can be selected as described in the GK-404 Manual.)

The GK-404 will continue to take measurements and display readings until the unit is turned off, either manually, or if enabled, by the Auto-Off timer. If no reading displays or the reading is unstable, consult Section 8 for troubleshooting suggestions.

For further information, please see the GK-404 manual.

6.4 GK-405 Readout Box

The GK-405 Vibrating Wire Readout is made up of two components: The Readout Unit, consisting of a Windows Mobile handheld PC running the GK-405 Vibrating Wire Readout Application; and the GK-405 Remote Module, which is housed in a weatherproof enclosure and connects via a cable to the vibrating wire gauge to be measured. The two components communicate wirelessly. The Readout Unit can operate from the cradle of the Remote Module, or, if more convenient, can be removed and operated up to 20 meters from the Remote Module.

6.4.1 Connecting Sensors with 10-pin Bulkhead Connectors Attached

Align the grooves on the sensor connector (male), with the appropriate connector on the readout (female connector labeled sensor or load cell). Push the connector into place, and then twist the outer ring of the male connector until it locks into place.

6.4.2 Connecting Sensors with Bare Leads

Attach the GK-403-2 flying leads to the bare leads of a Geokon vibrating wire sensor by connecting each of the clips on the leads to the matching colors of the sensor conductors, with blue representing the shield (bare).

6.4.3 Operating the GK-405

Press the button labeled “POWER ON”. A blue light will begin blinking, signifying that the Remote Module is waiting to connect to the handheld unit. Launch the GK-405 VWRA program by tapping on “Start” from the handheld PC’s main window, then “Programs” then the GK-405 VWRA icon. After a few seconds, the blue light on the Remote Module should stop flashing and remain lit. The Live Readings Window will be displayed on the handheld PC. Choose display mode “B”. Figure 13 shows a typical vibrating wire output in digits and thermistor output in degrees Celsius. If no reading displays or the reading is unstable, see Section 8 for troubleshooting suggestions. For further information, consult the GK-405 Instruction Manual.




Figure 13 - Live Readings – Raw Readings

6.5 GK-403 Readout Box (Obsolete Model)

The GK-403 can store gauge readings and apply calibration factors to convert readings to engineering units. The following instructions explain taking gauge measurements using Mode “B”. Consult the GK-403 Instruction Manual for additional information.

6.5.1 Connecting Sensors with 10-pin Bulkhead Connectors Attached

Align the grooves on the sensor connector (male), with the appropriate connector on the readout (female connector labeled sensor or load cell). Push the connector into place, and then twist the outer ring of the male connector until it locks into place.

6.5.2 Connecting Sensors with Bare Leads

Attach the GK-403-2 flying leads to the bare leads of a Geokon vibrating wire sensor by connecting each of the clips on the leads to the matching colors of the sensor conductors, with blue representing the shield (bare).

6.5.3 Operating the GK-403

- 1) Turn the display selector to position “B”.
- 2) Turn the unit on.
- 3) The readout will display the vibrating wire output in digits. The last digit may change one or two digits while reading.
- 4) The thermistor reading will be displayed above the gauge reading in degrees centigrade.
- 5) Press the “Store” button to record the value displayed.

If the no reading displays or the reading is unstable, see Section 8 for troubleshooting suggestions.

The unit will automatically turn off after approximately two minutes to conserve power.

7. DATA ANALYSIS

Raw data can be treated in several ways to reveal zones or planes of weakness in which movement is occurring. All raw data must be converted into time plots as soon as possible. Failure to plot the data in a timely manner can negate the purposes of the monitoring program. Inspection of the plots will show whether movements are steady, are accelerating, or have stopped. They may suggest the need for remedial measures and will be useful in monitoring their efficacy.

7.1 Example of MPBX Data Reduction Where the Deep Anchor is in Stable Ground

Table 1 shows a series of entries into a field book. In this example, Anchor 3 is located in stable ground.

Date	Anchor 3 (Depth 20 m) millimeters	Anchor 2 (Depth 10 m) millimeters	Anchor 1 (Depth 3 m) millimeters	Remarks
12/01/00	38.10	25.19	34.75	Initial Reading (R_0)
12/02/00	38.91	26.01	35.51	
12/03/00	39.01	26.11	35.61	
12/05/00	39.12	26.16	35.61	
12/06/00	39.14	26.16	35.61	
12/08/00	40.18	27.13	36.58	Blasting in the Area
12/09/00	40.13	27.18	36.63	
12/10/00	40.26	27.31	36.65	
12/11/00	40.64	27.61	36.65	
12/15/00	43.82	28.58	36.83	Heavy Rain
12/16/00	43.87	28.58	36.83	
12/18/00	43.94	28.63	36.88	
12/20/00	43.99	28.65	36.88	

Table 1 - Raw Data

The first task is to calculate the measured displacements between the head and each anchor. This can easily be done for each anchor, by subtracting the initial reading, R_0 from each of the subsequent readings. This creates the table of figures shown in Table 2.

Date	Anchor 3 (Depth 20 m) millimeters	Anchor 2 (Depth 10 m) millimeters	Anchor 1 (Depth 3 m) millimeters	Remarks
12/01/00	0.00	0.00	0.00	Installed
12/02/00	0.81	0.82	0.76	
12/03/00	0.91	0.92	0.86	
12/05/00	1.02	0.97	0.86	
12/06/00	1.04	0.97	0.86	
12/08/00	2.08	1.94	1.83	Blasting in the Area
12/09/00	2.03	1.99	1.88	
12/10/00	2.16	2.12	1.90	
12/11/00	2.54	2.42	1.90	
12/15/00	5.72	3.39	2.08	Heavy Rain
12/16/00	5.75	3.39	2.08	
12/18/00	5.84	3.44	2.13	
12/20/00	5.89	3.46	2.13	

Table 2 - Relative Movement between the Instrument Head and Each Anchor

However, in the example chosen, it is the deepest anchor that is stable, not the Instrument Head, so that the movement of each of the anchors should be calculated relative to Anchor 3 and not to the head of the MPBX. Immediately it will be realized that the apparent movement of Anchor 3 is actually the absolute movement of the instrument head relative to stable ground.

When the Instrument head is in stable ground, such as would be the case for a MPBX head located at street level in a borehole drilled downwards to terminate slightly above a tunnel being excavated below, then the measured movements on each anchor are taken directly from the readings on each anchor. The analysis of the data would then proceed as before without the need for the steps described below.

Date	Anchor 2 (Depth 10 m) millimeters	Anchor 1 (Depth 3 m) millimeters	Instrument Head millimeters	Remarks
12/01/00	0.00	0.00	0.00	Installed
12/02/00	0.01	0.05	0.81	
12/03/00	0.01	0.05	0.91	
12/05/00	0.05	0.16	1.02	
12/06/00	0.07	0.18	1.04	
12/08/00	0.14	0.25	2.08	Blasting in the Area
12/09/00	0.04	0.15	2.03	
12/10/00	0.04	0.26	2.16	
12/11/00	0.12	0.64	2.54	
12/15/00	2.33	3.64	5.72	Heavy Rain
12/16/00	2.36	3.67	5.75	
12/18/00	2.40	3.71	5.84	
12/20/00	2.43	3.76	5.89	

Table 3 - Movement of the Instrument Head and Anchors Relative to Anchor 3 in Stable Ground

The data shown in Table 3 could be plotted and shown in a graph like the one shown in Figure 14.




Figure 14 - Movement of the Head and Anchors Relative to Anchor 3 in Stable Ground

Inspection of the plot shows that initial movement occurred in the zone closest to the surface during the first three days and again on day eight following blasting in the area. On day 15, following a heavy rainfall, deep-seated movements occurred in the zone between Anchors 2 and 3 as well as in the shallower zones. Movements occurring in any inter-anchor zone can be inferred from the spacing between the individual plots of Figure 14, or they can be plotted separately as shown in Figure 15.




Figure 15 - Movements Occurring in Each Inter-Anchor Zone

8. TROUBLESHOOTING

The multiple anchor design tends to show confirming changes of readings on several rods from movements that affect more than one anchor. Bad readings on any intermediate anchor will tend to stand out as incompatible with the movements of the surrounding anchors. Nevertheless, it is possible that cracks in one zone might open while those in an adjacent zone might close.

8.1 Dial Indicators

Dial Indicators are delicate instruments and should always be kept clean and dry. It is advisable to have a Standard, which can be used to check that the dial gauge always gives the same reading when checked against this Standard. The Standard might be a block of steel in which a hole has been bored.

8.2 Vibrating Wire Transducers

Symptom: Displacement Transducer Readings are Unstable

- ✓ Is the readout box position set correctly? If using a datalogger to record readings automatically, are the swept frequency excitation settings correct? Try reading the displacement transducer on a different readout position. For instance, channel A of the GK-404 and GK-405 might be able to read the transducer.
- ✓ Is there a source of electrical noise nearby? Probable sources of electrical noise include motors, generators, transformers, arc welders, and antennas. Make sure the shield drain wire is connected to ground whether using a portable readout or datalogger. If using the GK-403, GK-404, or GK-405, connect the clip with the blue boot to the shield drain wire. (Green for the GK-401.)
- ✓ Does the readout work with another displacement transducer? If not, the readout may have a low battery or be malfunctioning. Consult the appropriate readout manual for charging or troubleshooting directions.
- ✓ Has the transducer gone outside its range? If so, the transducer can be reset using the installation instructions in Section 5.

Symptom: Displacement Transducer Fails to Read

- ✓ Is the cable cut or crushed? This can be checked with an ohmmeter. Nominal resistance between the two gauge leads (usually red and black leads) is 180Ω , $\pm 10\Omega$. Remember to add cable resistance when checking (22 AWG stranded copper leads are approximately $14.7\Omega/1000'$ or $48.5\Omega/\text{km}$, multiply by two for both directions). If the resistance reads very high or infinite (megohms), a cut wire must be suspected. If the resistance reads very low ($<100\Omega$), a short in the cable is likely.
- ✓ Does the readout or datalogger work with another transducer? If not, the readout or datalogger may be malfunctioning. Consult the readout or datalogger manual for further direction.

APPENDIX A. WIRING CHARTS FOR VIBRATING WIRE TRANSDUCERS

A.1 Single Transducer Wiring Chart

Internal Wiring	Geokon Cable #02-205V6 (Blue)	Function / Description
Red	Red	Gauge 1+
Black	Black	Gauge 1-
Red	White	Thermistor
Black	Green	Thermistor
N/C	Shield (1)	N/A

Table 4 - Wiring for One Transducer

A.2 Two Transducer Wiring Chart

Internal Wiring	Geokon Cable #04-375V9	Function / Description
Red	Red	Gauge 1+
Black	Black of Red	Gauge 1-
Red	White	Gauge 2+
Black	Black of White	Gauge 2-
Blue	Blue	Thermistor
Black of Blue	Black of Blue	Thermistor
N/C	Shields (4)	Ground

Table 5 - Wiring for Two Transducers

A.3 Three Transducers Wiring Chart

Internal Wiring	Geokon Cable #04-375V9 (Violet)	Function / Description
Red	Red	Gauge 1+
Black	Black of Red	Gauge 1-
Red	White	Gauge 2+
Black	Black of White	Gauge 2-
Red	Green	Gauge 3+
Black	Black of Green	Gauge 3-
N/C	Blue	Thermistor
N/C	Black of Blue	Thermistor
N/C	Shields (5)	Ground

Table 6 - Wiring for Three Transducers

A.4 Four Transducers Wiring Chart

Internal Wiring	Geokon Cable #05-375V12 (Tan)	Function / Description
Red	Red	Gauge 1+
Black	Black of Red	Gauge 1-
Red	White	Gauge 2+
Black	Black of White	Gauge 2-
Red	Green	Gauge 3+
Black	Black of Green	Gauge 3-
Red	Blue	Gauge 4+
Black	Black of Blue	Gauge 4-
N/C	Yellow	Thermistor
N/C	Black of Yellow	Thermistor
N/C	Shields (6)	Ground

Table 7 - Wiring for Four Transducers

A.5 Five Transducers Wiring Chart

Internal Wiring	Geokon Cable #06-500V7 (Orange)	Function / Description
Red	Red	Gauge 1+
Black	Black of Red	Gauge 1-
Red	White	Gauge 2+
Black	Black of White	Gauge 2-
Red	Green	Gauge 3+
Black	Black of Green	Gauge 3-
Red	Blue	Gauge 4+
Black	Black of Blue	Gauge 4-
Red	Yellow	Gauge 5+
Black	Black of Yellow	Gauge 5-
Red	Brown	Thermistor
Black	Black of Brown	Thermistor
N/C	Shields (7)	Ground

Table 8 - Wiring for Five Transducers

A.6 Six Transducers Wiring Chart

Internal Wiring	Geokon Cable #012-625V5 (Brown CAB-507)	Function / Description
Red	Red	Gauge 1+
Black	Black of Red	Gauge 1-
Red	White	Gauge 2+
Black	Black of White	Gauge 2-
Red	Green	Gauge 3+
Black	Black of Green	Gauge 3-
Red	Blue	Gauge 4+
Black	Black of Blue	Gauge 4-
Red	Yellow	Gauge 5+
Black	Black of Yellow	Gauge 5-
Red	Brown	Gauge 6+
Black	Black of Brown	Gauge 6-
White	White	Thermistor
Red of White	Red of White	Thermistor
N/C	Shields (8)	Ground

Table 9 - Wiring for Six Transducers

A.7 Seven Transducers Wiring Chart

Internal Wiring	Geokon Cable #012-625V5 (Brown)	Function / Description
Red	Red	Gauge 1+
Black	Black of Red	Gauge 1-
Red	White	Gauge 2+
Black	Black of White	Gauge 2-
Red	Green	Gauge 3+
Black	Black of Green	Gauge 3-
Red	Blue	Gauge 4+
Black	Black of Blue	Gauge 4-
Red	Yellow	Gauge 5+
Black	Black of Yellow	Gauge 5-
Red	Brown	Gauge 6+
Black	Black of Brown	Gauge 6-
Red	Orange	Gauge 7+
Black	Black of Orange	Gauge 7-
N/C	White	Thermistor
N/C	Red of White	Thermistor
N/C	Shields (9)	Ground

Table 10 - Wiring for Seven Transducers

A.8 Eight Transducers Wiring Chart

Internal Wiring	Geokon Cable #012-625V5 (Brown)	Function / Description
Red	Red	Gauge 1+
Black	Black of Red	Gauge 1-
Red	White	Gauge 2+
Black	Black of White	Gauge 2-
Red	Green	Gauge 3+
Black	Black of Green	Gauge 3-
Red	Blue	Gauge 4+
Black	Black of Blue	Gauge 4-
Red	Yellow	Gauge 5+
Black	Black of Yellow	Gauge 5-
Red	Brown	Gauge 6+
Black	Black of Brown	Gauge 6-
Red	Orange	Gauge 7+
Black	Black of Orange	Gauge 7-
Red	Red	Gauge 8+
Black	Green of Red	Gauge 8-
N/C	White	Thermistor
N/C	Red of White	Thermistor
N/C	Shields (10)	Ground

Table 11 - Wiring for Eight Transducers

APPENDIX B. SPECIFICATIONS

B.1 Model 1280 Specifications

Standard Range	Up to 300 mm nominal
Least Reading	0.025 mm
Borehole Diameter¹	50 mm minimum (for a single point)
Maximum Length	100 m

Table 12 - A-6 Extensometer Specifications

Notes:

¹ Note that the size of the borehole required increases with the addition of more measuring points.

B.2 Model 4450 Vibrating Wire Transducer Specifications

Standard Ranges¹ (mm)	12.5, 25, 50, 100, 150, 200, 230, 300
Resolution²	0.025% FSR
Linearity	0.25% FSR
Thermal Zero Shift³	< 0.05% FSR/°C
Stability	< 0.2%/yr (under static conditions)
Accuracy⁴	
Overrange	115%
Temperature Range	-20 to +80 °C
Frequency Range	1200 - 2800 Hz
Coil Resistance	180 Ω, ±10 Ω
Cable Type⁵	Two twisted pair (four conductor) 22 AWG Foil shield, PVC jacket, nominal OD=6.3 mm (0.250")

Table 13 - Model 4450 Displacement Transducer Specifications

Notes:

¹ Other ranges available on request.

² Minimum; greater resolution possible depending on readout.

³ Depends on application.

⁴ Accuracy established under laboratory conditions.

⁵ Polyurethane jacket cable available.

APPENDIX C. THERMISTOR TEMPERATURE DERIVATION

Thermistor Type: YSI 44005, Dale #1C3001-B3, Alpha #13A3001-B3
 Resistance to Temperature Equation:

$$T = \frac{1}{A+B(\ln R)+C(\ln R)^3} - 273.15 \text{ } ^\circ\text{C}$$

Equation 1 - Resistance to Temperature

Where;

T = Temperature in °C.

LnR = Natural Log of Thermistor Resistance

A = 1.4051 × 10⁻³

B = 2.369 × 10⁻⁴

C = 1.019 × 10⁻⁷

Note: Coefficients calculated over the -50 to +150 °C. span.

Ohms	Temp	Ohms	Temp	Ohms	Temp	Ohms	Temp	Ohms	Temp
201.1K	-50	16.60K	-10	2417	+30	525.4	+70	153.2	+110
187.3K	-49	15.72K	-9	2317	31	507.8	71	149.0	111
174.5K	-48	14.90K	-8	2221	32	490.9	72	145.0	112
162.7K	-47	14.12K	-7	2130	33	474.7	73	141.1	113
151.7K	-46	13.39K	-6	2042	34	459.0	74	137.2	114
141.6K	-45	12.70K	-5	1959	35	444.0	75	133.6	115
132.2K	-44	12.05K	-4	1880	36	429.5	76	130.0	116
123.5K	-43	11.44K	-3	1805	37	415.6	77	126.5	117
115.4K	-42	10.86K	-2	1733	38	402.2	78	123.2	118
107.9K	-41	10.31K	-1	1664	39	389.3	79	119.9	119
101.0K	-40	9796	0	1598	40	376.9	80	116.8	120
94.48K	-39	9310	+1	1535	41	364.9	81	113.8	121
88.46K	-38	8851	2	1475	42	353.4	82	110.8	122
82.87K	-37	8417	3	1418	43	342.2	83	107.9	123
77.66K	-36	8006	4	1363	44	331.5	84	105.2	124
72.81K	-35	7618	5	1310	45	321.2	85	102.5	125
68.30K	-34	7252	6	1260	46	311.3	86	99.9	126
64.09K	-33	6905	7	1212	47	301.7	87	97.3	127
60.17K	-32	6576	8	1167	48	292.4	88	94.9	128
56.51K	-31	6265	9	1123	49	283.5	89	92.5	129
53.10K	-30	5971	10	1081	50	274.9	90	90.2	130
49.91K	-29	5692	11	1040	51	266.6	91	87.9	131
46.94K	-28	5427	12	1002	52	258.6	92	85.7	132
44.16K	-27	5177	13	965.0	53	250.9	93	83.6	133
41.56K	-26	4939	14	929.6	54	243.4	94	81.6	134
39.13K	-25	4714	15	895.8	55	236.2	95	79.6	135
36.86K	-24	4500	16	863.3	56	229.3	96	77.6	136
34.73K	-23	4297	17	832.2	57	222.6	97	75.8	137
32.74K	-22	4105	18	802.3	58	216.1	98	73.9	138
30.87K	-21	3922	19	773.7	59	209.8	99	72.2	139
29.13K	-20	3748	20	746.3	60	203.8	100	70.4	140
27.49K	-19	3583	21	719.9	61	197.9	101	68.8	141
25.95K	-18	3426	22	694.7	62	192.2	102	67.1	142
24.51K	-17	3277	23	670.4	63	186.8	103	65.5	143
23.16K	-16	3135	24	647.1	64	181.5	104	64.0	144
21.89K	-15	3000	25	624.7	65	176.4	105	62.5	145
20.70K	-14	2872	26	603.3	66	171.4	106	61.1	146
19.58K	-13	2750	27	582.6	67	166.7	107	59.6	147
18.52K	-12	2633	28	562.8	68	162.0	108	58.3	148
17.53K	-11	2523	29	543.7	69	157.6	109	56.8	149
								55.6	150

Table 14 - Thermistor Resistance versus Temperature

APPENDIX D. USING A PULL-IN ANCHOR IN DEEP BOREHOLES

For deep boreholes oriented horizontally, upwards, or inclined downwards at a large angle to the vertical it may not be possible, due to the flexibility of the extensometer assembly, and friction against the walls of the borehole, to push the assembly all the way into the borehole. To overcome this problem a pull-in anchor should be used.

This pull-in anchor comprises a Bladder type Hydraulic Anchor of the same type as the other anchors. This pull-in anchor carries a pulley wheel so that a plastic-coated stainless steel aircraft cable can be threaded around the pulley and be used to pull the extensometer anchor string into place.

The pull-in anchor has a left-handed pipe thread adapter to enable the attachment of ¼ inch pipe sections, (available in 22 ft. sections), that can then be coupled together and used to push the pull-in anchor, with the aircraft cable looped around the pulley, to the back of the borehole. To disengage the rods from the deep anchor they can be turned clockwise.

Once in place the hydraulic bladder anchor is inflated. One end of the aircraft cable is now attached to the eyebolt on the underside of the bottom anchor of the extensometer string. Before pulling the extensometer into place, it is very important to trap the other intermediate depth hydraulic anchors onto the extensometer string so that as the string is pulled into the borehole the friction against the borehole walls does not cause the intermediate anchors to slide down the rod/tubing assemblies. To trap the anchors, it is recommended to use electrical tape to create a lump around the tubing immediately above each one of the intermediate depth anchors. The lumps should be big enough to prevent them from sliding through the holes in the hydraulic anchor.

The pull-in anchor also has the advantage of ensuring that the rod/tubing assemblies are pulled into a straight-line configuration, removing most of the friction that would occur between the rod and the tubes if they were snaked inside the borehole.